



# **COEP Technological University**

## **(COEP Tech)**

**A Unitary Public University of Government of Maharashtra  
(Formerly College of Engineering Pune)  
Wellesley Road, Shivajinagar, Pune-411005, Maharashtra, India**

### **Invitation of Quotations for**

**Supply of electrical items and their installation, testing and commissioning for UPS input & output connections at COEP Tech University, Pune. Shivaji Nagar, Wellesly Road, Pune, Maharashtra 411005.**

**Ref: COEP TECH/EWC/UPS input & output connection Work /2025-26/03.**

**Date: 09/05/2025**

**Website: <https://www.coeptech.ac.in>**

**Telephone Number: - 020 - 2550 - 7425**

**Contact Person 1. Dr. A. R. Phadke - 8888108570**



# COEP Technological University (COEP Tech)

A Unitary Public University of Government of Maharashtra  
(Formerly College of Engineering Pune)  
Wellesley Road, Shivajinagar, Pune-411005, Maharashtra, India

Ref: COEP TECH/ EWC/ UPS input & output connection Work. /2025\_26/03.Dated:09/05/2025.

## INVITATION OF QUOTATION

**Name of Work:** Supply of electrical items and their installation, testing and commissioning for UPS input & output connections at COEP Tech University, Pune. Shivaji Nagar, Wellesly Road, Pune, Maharashtra 411005.

Dear Sir,

You are invited to submit your most competitive quotation for **above work**. The details are as below:

| Sr No. | Item specification of good   | PWD CSR NO. | Make    | Unit     | Rate per unit with installation | Total Amount Rs. With installation |
|--------|--|-------------|---------|----------|---------------------------------|------------------------------------|
| 1.     | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 25 sq. mm. RED copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU    | 7-2-1       | Polycab | 40 meter |                                 |                                    |
| 2.     | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 25 sq. mm. YELLOW copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU | 7-2-1       | Polycab | 40 meter |                                 |                                    |

|    |  |         |         |          |  |  |
|----|--|---------|---------|----------|--|--|
| 3. | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 25 sq. mm. BLUE copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU   | 7-2-1   | Polycab | 40 meter |  |  |
| 4. | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 25 sq. mm. BLACK copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU  | 7-2-1   | Polycab | 40 meter |  |  |
| 5. | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 25 sq. mm. GREEN copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU  | 7-2-1   | Polycab | 40 meter |  |  |
| 6. | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 16 sq. mm. RED copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU    | NON CSR | Polycab | 80 meter |  |  |
| 7. | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 16 sq. mm. YELLOW copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU | NON CSR | Polycab | 80 meter |  |  |
| 8. | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 16 sq. mm. BLUE copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU   | NON CSR | Polycab | 80 meter |  |  |

|     |  |          |         |          |  |  |
|-----|--|----------|---------|----------|--|--|
| 9.  | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 16 sq. mm. BLACK copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU  | NOIN CSR | Polycab | 80 meter |  |  |
| 10. | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 16 sq. mm. GREEN copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU  | NON CSR  | Polycab | 80 meter |  |  |
| 11. | Supplying, erecting & terminating FR XLPE insulated, galvanised steel formed wire armoured (strip) cable 1100 V, 4 core 35 sq. mm. copper conductor complete erected with glands & lugs, on wall/ trusses/ pole or laid in provided trench/ pipe as per specification no. CB-LT/CU   | 7-2-36   | Polycab | 60 meter |  |  |
| 12. | Supplying, erecting & terminating FR XLPE insulated unarmoured cable 1100 V. 1 core 10 sq. mm. GREEN copper conductor complete erected with provided lugs, laid in provided control panel /distribution boards / pipe as per specification no. CB-LT/CU  | NON CSR  | Polycab | 30 meter |  |  |
| 13. | Providing & erecting 3 Pole MCCB, 415V, up to 100A, rated short-circuit breaking capacity 25 kA (Ics=100% of Icu), adjustable thermal (overload) setting and fixed magnetic setting with provided leads, provision for installation of shunt/UV/trip alarm contact. MCCB with phase barriers on both sides, insulation withstand capacity 800V, no line-load bias in provided enclosure/panel as per specification no. SW-MCCB | 5-5-1    | Legrand | 06       |  |  |

|     |  |       |                             |    |                              |  |
|-----|--|-------|-----------------------------|----|------------------------------|--|
| 14. | Supplying, installing and testing earthing with galvanised iron earth plate size 60 x 60 x 0.6 cm complete with all accessories of GI materials & recording the results as per specification No. EA-EP | 9-1-1 | Galvanized iron earth plate | 05 |                              |  |
|     |  |       |                             |    | <b>Basic Price Total Rs.</b> |  |
|     |  |       |                             |    | <b>GST @ 18% Price RS.</b>   |  |
|     |  |       |                             |    | <b>Grand Total Price Rs.</b> |  |
|     | Note:<br>1) Before the submission of quotation, the contractor should visit the site.<br>2) Extra LT cable, wires & MCCB if required, it will be paid extra at actual                                  |       |                             |    |                              |  |

### Terms and Conditions:

1. The bidder should attach the required document with the tender.
2. The bidder should submit GST registration document along with tender.
3. **Special Conditions for the work:**
  - a. COEP Technological University, Pune is not liable for any breach of any Government rules/regulations by Bidder/agency/firm or its employees. The Bidder/agency/firm will be solely responsible for their action.
  - b. If during work within the premises of COEP Technological University, Pune any mishap/accident occurs causing injuries to the employees or representatives of Bidder/agency/firm, necessary compensation as required by the statute will be borne by Bidder/agency/firm itself, and COEP Technological University, Pune is not responsible against all claims on such accounts.
  - c. All the staff deployed by Bidder/agency/firm will ensure that they are polite and courteous in their behavior. They shall carry their photo identity card prominently displayed during the repairing hours.
  - d. The bidder / agency / firm should be prepared to come to COEP Technological University, Pune to take part in the discussion, if required in this regard.
  - e. All work shall be carried out with due regard to the convenience of COEP Technological University, Pune. The orders of the authority concerned shall be strictly observed.

5. The taxes, insurance, freight, packing and forwarding charges if any must be quoted in Indian Rupees separately.
6. The rates shall be valid for 90 days.
7. Quotation(s) received after the last date of Quotation submission will be rejected.
8. All following documents/certificates should be provided / attached.
  - a) Shop Act License/Incorporation Certificate/Firm Registration Certificate Copy.
  - b) PAN Card Copy
  - c) GST Certificate Copy
  - d) Work experience certificate min. 3 years similar.
9. All duties, taxes, and other levies payable by the bidder need to be included in the total price and break up needs to be indicated.
10. The bidder shall have to quote all the items of the quotations. Part quotations/incomplete quotations shall be summarily rejected without any consideration.
11. The quotations shall be signed by an authorized person and the bidder's full name and status be indicated below the signature along with an official stamp of the vendor/firm/company.
12. Offers in the bid should be written in English and price should be written in both figures and words.
13. The supply/work should be completed within 2 weeks from the date of Work order.
14. No extension shall be given for supply/work/service. In such a case a penalty for delay in proportion to the cost of equipment/work/service. at the rate of 0.5 % per week; maximum limit of 10% shall be charged in case of PO value is less than 2 Lakh.
  - a. **In case of delay more than 3 weeks, beyond the stipulated complication of work date, order shall be deemed cancelled.**
  - b. Bidder shall be responsible for successful Installation, Commissioning and testing of the supplied devices at defined locations
15. The 100% bill for the above work will be paid immediately after successful commissioning and testing of the work. No advance payment will be given.
16. The COEP Technological University reserves the right to cancel any of the items of the tender without any reason thereof.
17. The quotations should be downloaded from the COEP Technological University website <https://www.coeptech.org.in/> tenders and submitted in the format given

above to Electrical Engineering Department, COEP Technological University Pune during working days.

18. The quotation should be duly signed and addressed to **The Vice Chancellor, COEP Technological University, Pune-5** and submitted in sealed envelope.
19. Quotations will not be received by E-mail / FAX.
20. The various time limits are as follows.

| <b>Activity</b>                      | <b>Date</b> | <b>Time</b> |
|--------------------------------------|-------------|-------------|
| Start of submission of quotation     | 14/05/2025  | 11.00 am    |
| Last date of submission of quotation | 21/05/2025  | 04.00 pm    |
| Opening of Quotations                | 21/05/2025  | 05.00 pm    |

**Sd/-**  
**Registrar**  
COEP Technological University, Pune.